

\*\*\*\*\*  
USACE / NAVFAC / AFCEC UFGS-07 21 13 (August 2023)

Preparing Activity: NAVFAC

-----  
Superseding  
UFGS-07 21 13 (February 2016)

## UNIFIED FACILITIES GUIDE SPECIFICATIONS

References are in agreement with UMRL dated April 2025

\*\*\*\*\*

### SECTION TABLE OF CONTENTS

#### DIVISION 07 - THERMAL AND MOISTURE PROTECTION

#### SECTION 07 21 13

#### BOARD AND BLOCK INSULATION

08/23

#### PART 1 GENERAL

- 1.1 REFERENCES
- 1.2 SUBMITTALS
- 1.3 MANUFACTURER'S DETAILS
- 1.4 PRODUCT DATA
- 1.5 CERTIFICATIONS
  - 1.5.1 Indoor Air Quality Certification
- 1.6 DELIVERY, STORAGE, AND HANDLING
  - 1.6.1 Delivery
  - 1.6.2 Storage
- 1.7 SAFETY PRECAUTIONS
  - 1.7.1 Respirators
  - 1.7.2 Other Safety Considerations
- 1.8 SPECIAL WARRANTIES
  - 1.8.1 Guarantee
  - 1.8.2 Warranty

#### PART 2 PRODUCTS

- 2.1 BLOCK OR BOARD INSULATION
  - 2.1.1 Thermal Resistance
  - 2.1.2 Fire Protection Requirements
  - 2.1.3 Recycled Materials
  - 2.1.4 Indoor Air Quality
  - 2.1.5 Prohibited Materials
- 2.2 VAPOR RETARDER AND DAMPPROOFING
  - 2.2.1 Vapor Retarder in Framed Walls and Roofs
  - 2.2.2 Dampproofing for Masonry Cavity Walls
- 2.3 PRESSURE SENSITIVE TAPE
- 2.4 PROTECTION BOARD OR COATING
- 2.5 ACCESSORIES
  - 2.5.1 Adhesive
  - 2.5.2 Mechanical Fasteners

PART 3 EXECUTION

- 3.1 EXISTING CONDITIONS
- 3.2 PREPARATION
  - 3.2.1 Blocking Around Heat Producing Devices
- 3.3 INSTALLATION
  - 3.3.1 Insulation Installation and Handling
  - 3.3.2 Electrical Wiring
  - 3.3.3 Cold Climate Requirement
  - 3.3.4 Continuity of Insulation
  - 3.3.5 Coordination
- 3.4 INSTALLATION ON WALLS
  - 3.4.1 Installation using Furring Strips
  - 3.4.2 Installation on Masonry Walls
  - 3.4.3 Adhesive Attachment to Concrete and Masonry Walls
  - 3.4.4 Mechanical Attachment on Concrete and Masonry Walls
  - 3.4.5 Protection Board or Coating Installation
- 3.5 INSTALLATION ON UNDERSIDE OF CONCRETE FLOOR SLAB
  - 3.5.1 Mechanically Fastened Systems
  - 3.5.2 Adhesively Bonded Systems
- 3.6 PERIMETER AND UNDER SLAB INSULATION
  - 3.6.1 Manufacturer's Instructions
  - 3.6.2 Insulation on Vertical Surfaces
  - 3.6.3 Insulation Under Slab
  - 3.6.4 Protection of Insulation
- 3.7 VAPOR RETARDER
- 3.8 ACCESS PANELS AND DOORS

-- End of Section Table of Contents --

\*\*\*\*\*  
USACE / NAVFAC / AFCEC UFGS-07 21 13 (August 2023)

-----  
Preparing Activity: NAVFAC Superseding  
UFGS-07 21 13 (February 2016)

UNIFIED FACILITIES GUIDE SPECIFICATIONS

References are in agreement with UMRL dated April 2025

\*\*\*\*\*

SECTION 07 21 13

BOARD AND BLOCK INSULATION  
08/23

\*\*\*\*\*

NOTE: This guide specification covers the requirements for board and block thermal insulation.

Adhere to UFC 1-300-02 Unified Facilities Guide Specifications (UFGS) Format Standard when editing this guide specification or preparing new project specification sections. Edit this guide specification for project specific requirements by adding, deleting, or revising text. For bracketed items, choose applicable item(s) or insert appropriate information.

Remove information and requirements not required in respective project, whether or not brackets are present.

Comments, suggestions and recommended changes for this guide specification are welcome and should be submitted as a Criteria Change Request (CCR).

\*\*\*\*\*

\*\*\*\*\*

NOTE: This guide specification is intended for both retrofit of existing buildings and new construction.

\*\*\*\*\*

\*\*\*\*\*

NOTE: Specify board-type insulations for masonry and concrete walls and under concrete floor slabs. Also specify board-type insulation where the type of construction favors their economical usage and their application would be less difficult than blanket or loose fill insulations.

\*\*\*\*\*

\*\*\*\*\*

NOTE: On the drawings, show:

1. Locations where insulation must be used.

2. Thermal resistance value (R-Value) for each location.
3. Location of vapor retarder, if required.
4. Method of attachment of insulation board.
5. Location and size of attic ventilation openings where required.

\*\*\*\*\*

\*\*\*\*\*

NOTE: Attic Ventilation

1. Provide net, unobstructed ventilation areas to attics over insulated ceilings as recommended by International Building Code (IBC) paragraph 1202.02 Roof Ventilation, ASHRAE Handbook of Fundamentals, Chapter 25, Heat, Air, and Moisture Control in Building Assemblies - Fundamentals, and as follows:
2. For attics with vapor retarder, provide 0.1 square meter of net ventilation area for each 30 square meters of attic floor area.
3. For attics without vapor retarder, provide 0.1 square meter of net ventilation area for each 15 square meters of attic floor area.
4. For insulation of cathedral ceilings, provide at least a 50 mm gap between upper face of insulation and underside of roof sheathing. Provide ventilation openings at bottom and top of ventilated cavity; show on drawings.

\*\*\*\*\*

PART 1 GENERAL

1.1 REFERENCES

\*\*\*\*\*

NOTE: This paragraph is used to list the publications cited in the text of the guide specification. The publications are referred to in the text by basic designation only and listed in this paragraph by organization, designation, date, and title.

Use the Reference Wizard's Check Reference feature when you add a Reference Identifier (RID) outside of the Section's Reference Article to automatically place the reference in the Reference Article. Also use the Reference Wizard's Check Reference feature to update the issue dates.

References not used in the text will automatically be deleted from this section of the project specification when you choose to reconcile

**references in the publish print process.**

\*\*\*\*\*

The publications listed below form a part of this specification to the extent referenced. The publications are referred to within the text by the basic designation only.

ASTM INTERNATIONAL (ASTM)

ASTM C578	(2023) Standard Specification for Rigid, Cellular Polystyrene Thermal Insulation
ASTM C612	(2014; R 2019) Standard Specification for Mineral Fiber Block and Board Thermal Insulation
ASTM C930	(2019; R 2025) Standard Classification of Potential Health and Safety Concerns Associated with Thermal Insulation Materials and Accessories
ASTM C1289	(2023a) Standard Specification for Faced Rigid Cellular Polyisocyanurate Thermal Insulation Board
ASTM C1902	(2022) Standard Specification for Cellular Glass Insulation Used in Building and Roof Applications
ASTM D3833/D3833M	(1996; R 2019) Standard Test Method for Water Vapor Transmission of Pressure-Sensitive Tapes
ASTM D4397	(2016; R 2023) Standard Specification for Polyethylene Sheeting for Construction, Industrial, and Agricultural Applications
ASTM E84	(2024) Standard Test Method for Surface Burning Characteristics of Building Materials
ASTM E96/E96M	(2024a) Standard Test Methods for Gravimetric Determination of Water Vapor Transmission Rate of Materials

INTERNATIONAL CODE COUNCIL (ICC)

ICC IBC	(2024) International Building Code
---------	------------------------------------

NATIONAL FIRE PROTECTION ASSOCIATION (NFPA)

NFPA 31	(2024; TIA 23-1) Standard for the Installation of Oil-Burning Equipment
NFPA 54	(2024) National Fuel Gas Code
NFPA 70	(2026) National Electrical Code
NFPA 211	(2019) Standard for Chimneys, Fireplaces,

Vents, and Solid Fuel-Burning Appliances

SCIENTIFIC CERTIFICATION SYSTEMS (SCS)

SCS

SCS Global Services (SCS) Indoor Advantage

U.S. NATIONAL ARCHIVES AND RECORDS ADMINISTRATION (NARA)

29 CFR 1910.134

Respiratory Protection

UL SOLUTIONS (UL)

UL 2818

(2022) GREENGUARD Certification Program  
For Chemical Emissions For Building  
Materials, Finishes And Furnishings

U.S. DEPARTMENT OF DEFENSE (DOD)

UFC 3-600-01

(2016; with Change 6, 2021) Fire  
Protection Engineering for Facilities

KOREA AIR CLEANING ASSOCIATION (KACA)

SPS-KACA0020-7174

(2016; R 2022) Healthy Building Material

KOREAN INDUSTRIAL STANDARDS (KS)

KS F 4924

(2021) Plastic Films Vapour Barrier for  
Buildings

KS L 9102

(2014; R 2024) Artificial Mineral Fiber  
Thermal Insulation Materials

KS M 3848

(2024) Cellular Polystyrene (PS) Thermal  
Insulation Board to Prevent Condensation

KS M ISO 4898

(2024) Rigid Cellular Plastics - Thermal  
Insulation Products for Buildings -  
Specifications

## 1.2 SUBMITTALS

\*\*\*\*\*

NOTE: Review Submittal Description (SD) definitions in Section 01 33 00 SUBMITTAL PROCEDURES and edit the following list, and corresponding submittal items in the text, to reflect only the submittals required for the project. The Guide Specification technical editors have classified those items that require Government approval, due to their complexity or criticality, with a "G". Generally, other submittal items can be reviewed by the Contractor's Quality Control System. Only add a "G" to an item if the submittal is sufficiently important or complex in context of the project.

For Army projects, fill in the empty brackets following the "G" classification, with a code of up to three characters to indicate the approving

authority. Codes for Army projects using the Resident Management System (RMS) are: "AE" for Architect-Engineer; "DO" for District Office (Engineering Division or other organization in the District Office); "AO" for Area Office; "RO" for Resident Office; and "PO" for Project Office. Codes following the "G" typically are not used for Navy and Air Force projects.

The "S" classification indicates submittals required as proof of compliance for sustainability Guiding Principles Validation or Third Party Certification and as described in Section 01 33 00 SUBMITTAL PROCEDURES.

Choose the first bracketed item for Navy and Air Force projects, or choose the second bracketed item for Army projects.

\*\*\*\*\*

Government approval is required for submittals with a "G" or "S" classification. Submittals not having a "G" or "S" classification are for information only. When used, a code following the "G" classification identifies the office that will review the submittal for the Government. Submit the following in accordance with Section 01 33 00 SUBMITTAL PROCEDURES:

#### SD-02 Shop Drawings

Manufacturer's Standard Details; G

#### SD-03 Product Data

Environmental Data for Materials; G

Block or Board Insulation; G

[ Vapor Retarder; G

] Pressure Sensitive Tape; G

Protection Board or Coating; G

Accessories including sealants; G

Recycled Content for Block or Board Insulation; S

#### SD-07 Certificates

Indoor Air Quality For Block Or Board Insulation; S

#### SD-08 Manufacturer's Instructions

Insulation Installation and Handling

Protection Board or Coating Installation

Adhesive

#### SD-11 Closeout Submittals

Draft Guarantee; G

Final Guarantee; G

Draft Warranty; G

Final Warranty; G

#### 1.3 MANUFACTURER'S DETAILS

Submit [manufacturer's standard details](#) indicating methods of attachment and spacing, transition and termination details, and installation details. Include verification of existing conditions.

#### 1.4 PRODUCT DATA

Include [environmental data for materials](#) descriptions, recommendations for product shelf life, requirements for protection board or coatings, and precautions for flammability and toxicity. Include data to verify compatibility of sealants with insulation.

#### 1.5 CERTIFICATIONS

##### [1.5.1 Indoor Air Quality Certification

\*\*\*\*\*

NOTE: Based on the type of insulation included in the project, Designer should research the Greenguard certified products available and include this paragraph if products can be obtained from three or more manufacturers. Recent research has shown that Greenguard certified products are available from at least two national manufacturers for both extruded preformed cellular polystyrene (XPS) and polyisocyanurate insulation products.

\*\*\*\*\*

Provide products certified to meet indoor air quality requirements by [UL 2818](#) (Greenguard) Gold, [SCS Global Services Indoor Advantage Gold](#) or provide certification by other third-party programs. For locally manufactured construction materials, Korea Air Cleaning Association (KACA) HB Very Best in accordance with [SPS-KACA0020-7174](#) is also acceptable. Provide current product certification documentation from certification body.

##### ]1.6 DELIVERY, STORAGE, AND HANDLING

###### 1.6.1 Delivery

Deliver materials to the site in original sealed wrapping bearing manufacturer's name and brand designation, specification number, type, grade, R-value, and class. Store and handle to protect from damage. Do not allow insulation materials to become wet, soiled, crushed, or covered with ice or snow. Comply with manufacturer's recommendations for handling, storing, and protecting of materials before and during installation.



### 1.6.2 Storage

Inspect materials delivered to the site for damage and store out of weather in manufacturer's original packaging. Store only in dry locations, not subject to open flames or sparks, and easily accessible for inspection and handling. Keep materials wrapped and separated from off-gassing materials (such as drying paints and adhesives). Do not use materials that have visible moisture or biological growth. Comply with manufacturer's recommendations for handling, storage, and protection of materials before and during installation.

## 1.7 SAFETY PRECAUTIONS

### 1.7.1 Respirators

\*\*\*\*\*  
**NOTE: Include this paragraph only for installations in which mineral fibers are released into the atmosphere, such as where mineral fiber boards are cut on the job site.**  
\*\*\*\*\*

Where mineral fiber boards are cut on the job site, provide installers with dust/mist respirators, training in their use, and protective clothing, all approved by the National Institute for Occupational Safety and Health (NIOSH)/Mine Safety and Health Administration (MSHA) and in accordance with 29 CFR 1910.134.

### 1.7.2 Other Safety Considerations

Comply with the safety requirements of ASTM C930.

## 1.8 SPECIAL WARRANTIES

### 1.8.1 Guarantee

Guarantee insulation installation against failure due to ultraviolet light exposure for a period of three years from the date of Beneficial Occupancy or Substantial Completion. Submit draft guarantee and final guarantee in accordance with Sections 01 78 00 CLOSEOUT SUBMITTALS.

### 1.8.2 Warranty

Provide manufacturer's material warranty for all system components for a period of three years from the date of Beneficial Occupancy or Substantial Completion. Submit draft warranty and final warranty in accordance with Sections 01 78 00 CLOSEOUT SUBMITTALS.

## PART 2 PRODUCTS

\*\*\*\*\*  
**NOTE: Specify sustainable materials in accordance with UFC 1-200-02 HIGH PERFORMANCE AND SUSTAINABLE BUILDING REQUIREMENTS. Reduce the environmental impact of materials by specifying products that have a lesser or reduced effect on human health and the environment such as low emitting materials and materials with high recycled content. Consider product life cycle when compared with competing**

products or services serving the same purpose.

## 2.1 BLOCK OR BOARD INSULATION

NOTE: Select material and type of insulation board based on project design and application requirements regarding strength, vapor resistance, water absorption, and manufacturer's recommendations.

Provide thermal insulating materials as recommended by manufacturer for each type of application indicated. Provide insulation with the following physical properties and in accordance with the following standards:

- a. Faced Rigid Cellular Polyisocyanurate and Polyurethane Insulation: [ASTM C1289](#) REV A or [KS M ISO 4898](#)

(1) Type I Aluminum Foil on both major surfaces. Class 1 - Non-reinforced core foam or Class 2 - Glass fiber reinforced core.

(2) Type II Fibrous felt or glass fiber mat membrane on both major surfaces of the core foam.

NOTE: Select type of XPS insulation based on project requirements. The most common one is Type IV; other Types include X, VI, VII, and V with the primary difference being compressive resistance. XPS Types also have some differences in water vapor permeance, flexural strength and density.

- b. Extruded Preformed Cellular Polystyrene (XPS): [ASTM C578](#) REV A or [KS M 3848](#)

NOTE: Select type of mineral fiber board insulation based on project requirements. The most common one is Type IVB; other Types include IA thru V with the primary difference being compressive resistance and density.

- c. Mineral Fiber Block and Board: [ASTM C612](#) or [KS L 9102](#)

- d. Cellular Glass: [ASTM C1902](#)

### 2.1.1 Thermal Resistance

NOTE: Board and block thermal insulating materials have different thermal properties. Specify insulation to provide R-Values required to comply with UFC 3-101-01, Chapter Exterior Walls. Indicate R-values on the project drawings.

NOTE: Where board insulation is installed in

masonry cavity walls, size the wall cavity to  
accommodate the insulation thickness required to  
provide the specified R-Value and a 25 mm air space.

\*\*\*\*\*

As indicated.

#### ]2.1.2 Fire Protection Requirements

\*\*\*\*\*

**NOTE: Fire Safety Provisions**

1. Most vapor retarder materials and some thermal insulations are combustible. Do not leave such material exposed to accessible spaces, but cover with fire retardant finish.

2. See UFC 3-600-01 Fire Protection Engineering for Facilities and local building codes for required fire retardant classifications, flame spread and smoke developed ratings, distance of insulation and vapor retarders from heat producing devices, and other fire protection requirements such as finish materials in various occupancies.

\*\*\*\*\*

\*\*\*\*\*

**NOTE:** Do not use cellular plastic insulation exposed to the building interior. Separate the insulation from the interior according to the requirements of ICC IBC Chapter 26 Plastics Section 2603.4 Thermal Barrier or by a minimum of a 15-minute fire separation; comply with the most restrictive requirement. If no separation can be provided, select cellular glass block insulation instead of cellular plastic insulation. Edit this paragraph and the paragraph INSULATION ON VERTICAL SURFACES as required.

\*\*\*\*\*

\*\*\*\*\*

**NOTE:** Specify insulated roof assemblies in accordance with UFC 1-200-01 Fire and Smoke Protection Features section, and UFC 3-600-01. Where requirements conflict between UFCs and IBC, UFC 3-600-01 takes precedence; edit the following section accordingly.

\*\*\*\*\*

- a. Flame spread index of 75 or less when tested in accordance with ASTM E84.
- b. Smoke developed index of 150 or less when tested in accordance with ASTM E84.
- c. Exposed insulation in concealed spaces of sprinklered buildings must be specified to have a flame spread of 25 or less and a smoke developed rating of 50 or less.

- d. Provide insulated assemblies in accordance ICC IBC Chapter Fire and Smoke Protection Features.
- e. Exceptions are described in UFC 3-600-01, paragraph "FLAME SPREAD - NO SMOKE DEVELOPMENT RATING LIMITATION" and "NO FLAME SPREAD OR SMOKE LIMITATION".

#### 2.1.3 Recycled Materials

Provide thermal insulation containing recycled materials to the extent practicable, provided that the material meets all other requirements of this section.

Provide data identifying percentage of recycled content for block or board insulation.

#### 2.1.4 Indoor Air Quality

Provide certification of indoor air quality for block or board insulation.

#### 2.1.5 Prohibited Materials

Do not provide materials containing asbestos.

### [2.2 VAPOR RETARDER AND DAMPPROOFING

\*\*\*\*\*

#### NOTE:

1. Determine the need for a water vapor retarder and its required permance value based on project requirements and climate specific moisture analysis as required by UFC 3-101-01 Architecture. For guidance see ASHRAE Handbook of Fundamentals, Chapter 25, "Heat, Air, and Moisture Control in Building Assemblies - Fundamentals;" and ASTM C755, "Selection of Vapor Retarders for Thermal Insulations". The need for a vapor retarder and its permance must be evaluated in the moisture analysis with the Air and Moisture Barrier system specified. The computer Program "MOIST" is a user-friendly tool based on hourly weather data that provides information on moisture content of materials and on the duration of high moisture content excursions. Traditionally, vapor retarders for walls and roofs were considered materials having a permance of 5.72 by 10-8 g/Pa.s.m2 or less. Vapor retarders under slabs are typically specified as 1.14 by 10-8 g/Pa.s.m2 (0.2 Perm) or less. However, these values may not be adequate for a particular project or climate and in some instances a much lower value should be specified.

2. Vapor retarders, where required, can be provided as membranes or, alternatively, vapor retardant finishes labeled by the manufacturer as having a water vapor permance of no more than the required value. Alternate materials include: coatings or foil-faced gypsum board. Specify these in Section 09 90 00 PAINTS AND COATINGS or Section 09 29 00

GYPSUM BOARD respectively, and delete all paragraphs and references relating to vapor retarders from this section.

3. A vapor retarder is only effective if it prevents diffusion of water vapor as well as the passage of moisture laden air through openings and around material. Accordingly, proper installation to assure air tightness by sealing of joints, tears, and around utility penetrations is as important as proper selection of water vapor retarder materials. Coordinate specifications to comply with UFC 3-101-01 Architecture, Chapter Exterior Walls.

4. Vapor retarders not only retard movement of water vapor into building envelope assemblies and cavities, but also retard drying of moisture that may have infiltrated these areas. Therefore, use vapor retarders only when and where the moisture analysis indicates they are necessary.

\*\*\*\*\*

#### 2.2.1 Vapor Retarder in Framed Walls and Roofs

- a. 0.15 mm thick polyethylene sheeting conforming to ASTM D4397 and having a water vapor permeance of 5.72 by 10-8g/Pa.s.m2 or less when tested in accordance with ASTM E96/E96M.
- b. Local polyethylene sheets conforming to KS F 4924 are also acceptable.

#### [2.2.2 Dampproofing for Masonry Cavity Walls

Bituminous material is specified in Section 07 11 13 BITUMINOUS DAMPPROOFING.

#### ]2.3 PRESSURE SENSITIVE TAPE

As recommended by manufacturer of vapor retarder(s). Match water vapor permeance rating for each vapor retarder specified. Provide tape in accordance with ASTM D3833/D3833M.

#### 2.4 PROTECTION BOARD OR COATING

As recommended by insulation manufacturer.

#### 2.5 ACCESSORIES

##### 2.5.1 Adhesive

As recommended by insulation manufacturer.

##### 2.5.2 Mechanical Fasteners

Corrosion resistant fasteners as recommended by the insulation manufacturer.

PART 3 EXECUTION

3.1 EXISTING CONDITIONS

\*\*\*\*\*

Note: For retrofit projects, inspect facility to determine conditions which may adversely affect execution of work or create safety hazard. Identify relevant conditions on the drawings and, if required, develop additional specification sections for corrective actions. Conditions that warrant investigation:

1. Discolorations or mold growth indicating previous water leaks.
2. Heat producing devices, such as recessed lighting fixtures, chimneys, and flues.
3. Faulty electrical systems:
  - (a) Lights dimming or flickering
  - (b) Fuses blowing
  - (c) Circuit breakers tripping frequently
  - (d) Electrical sparks and "glowing" from receptacles
  - (e) Cover plates on switches and outlets warm to touch.

\*\*\*\*\*

Prior to installation, ensure all areas that will be in contact with the insulation are dry and free of projections that could cause voids, compressed insulation, or punctured vapor retarders. For foundation perimeter or under slab applications, check that subsurface fill is flat, smooth, dry, and well tamped. Do not proceed with installation if moisture or other conditions are present and notify the Contracting Officer of such conditions. Do not proceed with the work until conditions have been corrected and verified to be dry.

3.2 PREPARATION

3.2.1 Blocking Around Heat Producing Devices

Provide noncombustible blocking at all spaces between heat producing devices and the floors, ceilings and roofs through which they pass. Provide in accordance with ICC IBC Section 2111.13 Fireplace Fireblocking and with the following clearances:

- a. Recessed lighting fixtures, including wiring compartments, ballasts, and other heat producing devices, unless certified for installation surrounded by insulation: 75 mm from outside face of fixtures and devices or as required by NFPA 70 and, if insulation is placed above fixture or device, 600 mm above fixture.
- b. Masonry chimneys or masonry enclosing a flue: 50 mm from outside face of masonry. Masonry chimneys for medium and high heat operating

appliances: Minimum clearances required by NFPA 211.

- c. Vents and vent connectors used for venting products of combustion, flues, and chimneys other than masonry chimneys: Minimum clearances as required by NFPA 211.
- d. Gas Fired Appliances: Clearances as required in NFPA 54.
- e. Oil Fired Appliances: Clearances as required in NFPA 31.

Blocking is not required if chimneys or flues are certified in writing by the chimney or flue manufacturer for use in contact with specific insulating materials.

### 3.3 INSTALLATION

#### 3.3.1 Insulation Installation and Handling

Provide insulation in accordance with the manufacturer's printed installation instructions. Keep material dry and free of extraneous materials.

#### 3.3.2 Electrical Wiring

Do not install insulation in a manner that would enclose electrical conductors, that are not installed in conduit, between two layers of insulation.

#### [3.3.3 Cold Climate Requirement

\*\*\*\*\*  
**NOTE: Include this paragraph in ASHRAE climate zones 4 and higher, as identified in ASHRAE 90.1.**  
\*\*\*\*\*

Place insulation on the outside of pipes.

#### ]3.3.4 Continuity of Insulation

Butt tightly against adjoining boards, studs, rafters, joists, sill plates, headers and obstructions. Provide continuity and integrity of insulation at corners, wall to ceiling joint, roof, and floor. Avoid creating thermal bridges and voids. Provide and verify continuity of insulative barrier throughout the building enclosure.

\*\*\*\*\*  
**NOTE: Foil sided board reflects heat. Indicate on drawings the side on which the foil is to be faced. Coordinate use with mechanical designer.**

**To avoid thermal bridging, verify the drawings provide a layer of continuous insulation over studs.**

\*\*\*\*\*

#### 3.3.5 Coordination

Verify final installed insulation thicknesses comply with thicknesses indicated and with the approved insulation submittal(s).

### 3.4 INSTALLATION ON WALLS

#### 3.4.1 Installation using Furring Strips

Install insulation [between] [on] members as recommended by insulation manufacturer.

#### 3.4.2 Installation on Masonry Walls

\*\*\*\*\*  
**NOTE: Use the first paragraph below for insulation on the outside or inside of masonry walls. Use the second paragraph for insulating individual masonry units within their hollow cores. Insulating just the cores can lead to thermal bridges and condensation at the web locations of the masonry units.**  
\*\*\*\*\*

[ Apply board directly to masonry with adhesive or fasteners as recommended by the insulation manufacturer. Fit between obstructions without impaling board on ties or anchors. Apply in parallel courses with joints breaking midway over course below. Place boards in moderate contact with adjoining insulation without forcing and without gaps. Cut and shape as required to fit around wall penetrations, projections or openings to accommodate conduit or other utilities. Seal around cutouts with sealant. Install insulation in wall cavities so that it leaves at least a nominal 25 mm air space outside of the insulation to allow for cavity drainage.

#### 3.4.3 Adhesive Attachment to Concrete and Masonry Walls

Apply adhesive to wall and completely cover wall with insulation.

- [ a. Full back bed method [or]
- ] [b. Spot method: Provide at least six spots having diameter of approximately 100 mm, located at each corner and mid points of each of the longer sides of each board.
- ] [c. As recommended by the insulation manufacturer.
- ] d. Use only full back method for pieces of 0.1 square meter or less.
  - e. Butt all edges of insulation and seal edges with tape.

#### 3.4.4 Mechanical Attachment on Concrete and Masonry Walls

Cut insulation to cover walls. Apply adhesive to wall and set clip or other mechanical fastener in adhesive as recommended by manufacturer. After curing of adhesive, install insulation over fasteners and bend split prongs to provide a flush condition with the insulation. Butt all edges of insulation and seal with tape.

#### 3.4.5 Protection Board or Coating Installation

Install protection board or coating in accordance with manufacturer's printed instructions. Install protection over all exterior exposed insulation and to 300 mm below grade.



]3.5 INSTALLATION ON UNDERSIDE OF CONCRETE FLOOR SLAB

[3.5.1 Mechanically Fastened Systems

Size insulation to cover underside of slab. Apply adhesive to slab and set fasteners in adhesive as recommended by manufacturer. After curing of adhesive, install insulation over fasteners and bend split prongs to provide a flush condition with the insulation. Butt all edges of insulation and seal with tape.

][3.5.2 Adhesively Bonded Systems

Apply adhesive to underside of slab and completely cover wall with insulation.

[ a. Full back bed method [or]

] [b. Spot method: Provide at least six spots having a diameter of approximately 100 mm, located at each corner and mid-point of each of the longer sides.

] [c. As recommended by insulation manufacturer.

] d. Use full back method for insulation pieces 0.1 square meter or less.

e. Butt all edges of insulation and seal with tape.

]3.6 PERIMETER AND UNDER SLAB INSULATION

Install perimeter thermal insulation where heated spaces are adjacent to exterior walls, slab edges in slab-on-grade, or floating slab construction.

\*\*\*\*\*

**NOTE: Provide for and coordinate foundation  
draining as required by insulation manufacturer.**

**Provide R-Values and extent in accordance with the  
requirements of ASHRAE 90.1 for the project-specific  
climate zone.**

\*\*\*\*\*

3.6.1 Manufacturer's Instructions

Layout insulation, tape edges, provide vapor retarder and other required accessories to protect against vermin, insects, and damage in accordance with manufacturer's printed instructions.

[3.6.2 Insulation on Vertical Surfaces

Provide thermal insulation [on exterior of foundation walls] [on grade beams] [partially] [below grade] [and] [on edges of slabs-on-grade.] Fasten insulation with [adhesive] [or] [mechanical fasteners].

] [3.6.3 Insulation Under Slab

Provide insulation horizontally under [entire] slab on grade[ for a distance of [\_\_\_\_\_] mm from the edge of slab]. [ Turn insulation up at slab edge, and extend full height of slab.] Install insulation on top of vapor retarder and turn retarder up over the outside edge of insulation to

top of slab.

][3.6.4 Protection of Insulation

Protect insulation from damage during construction and back filling by application of protection board or a coating. Do not leave installed vertical insulation unprotected overnight. Protect installed insulation from weather, including rain and ultraviolet light, from mechanical abuse, compression, and dislocation.[ Install protection over entire exposed exterior insulation board.][ Extend protection at least 300 mm below grade.]

][3.7 VAPOR RETARDER

Apply vapor retarder continuous across all surfaces. Overlap all joints at least 150 mm and seal with pressure sensitive tape. Seal at sills, header, windows, doors and utility penetrations. Repair punctures or tears with pressure sensitive tape.

][3.8 ACCESS PANELS AND DOORS

Attach insulation to all access panels greater than 0.1 square meter and all access doors in insulated floors and ceilings. Use insulation with same R-Value as that for the floor or ceiling in which each panel occurs.

] -- End of Section --